



UK Declaration of Conformity

For the following equipment :

Product Name: Switching Power Supply

Model Designation: XTR-960-yyZZZZ (yy = 24, 36 or 48; each Z = 0~9, A~Z, a~z or blank for market purpose)

The designated product(s) is(are) in conformity with the relevant legislation:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012: SI 2012 No. 3032

Electrical Equipment (Safety) Regulations 2016 :

BS EN 62368-1:2014+A11

TUV certificate No : R50680034

BS EN IEC 61558-1:2019, BS EN 61558-2-16:2009+A1

TUV certificate No : R50682765

BS EN 61010-1:2010+A1, BS EN IEC 61010-2-201:2018

TUV certificate No : R50689932

Electrical Compatibility Regulations 2016 :

EMI (Electro-Magnetic Interference)

Conducted emission BS EN 55032:2015+A1:2020 Class B

Radiated emission BS EN 55032:2015+A1:2020

Harmonic current BS EN IEC 61000-3-2:2019+A1:2021

Voltage flicker BS EN 61000-3-3:2013+A1:2019+A2:2021

EMS (Electro-Magnetic Susceptibility)

BS EN 55035:2017+A11:2020 BS EN IEC 61000-6-2:2019

ESD air BS EN 61000-4-2:2009 Level 4 15KV

ESD contact BS EN 61000-4-2:2009 Level 4 8KV

RF field susceptibility BS EN IEC 61000-4-3:2020 Level 3 10V/m

EFT bursts BS EN 61000-4-4:2012 Level 4 4KV/5KHz

Surge susceptibility BS EN 61000-4-5:2014+A1:2017 Level 4 2KV/Line-Line

Surge susceptibility BS EN 61000-4-5:2014+A1:2017 Level 4 4KV/Line-Earth

Conducted susceptibility BS EN IEC 61000-4-6:2023 Level 3 10V

Magnetic field immunity BS EN 61000-4-8:2010 Level 4 30A/m

Voltage dip, interruption BS EN IEC 61000-4-11:2020 <5% residual voltage for 0.5 cycles, 70% residual voltage for 25 cycles, <5% residual voltage for 250 cycles

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Regulations on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number SC5xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Eris Wu/ Director, Group R&D :

(Name / Position)

Taiwan

(Place)

(Signature)

Aug. 8th, 2025

(Date)

Alex Tsai/ Director, Product Strategy Center :

(Name / Position)

(Signature)